



Good Life. Great Resources.

DEPT. OF WATER, ENERGY, AND ENVIRONMENT

Lead and Copper Results Report ("Form 5")			
Name of System:		City of Hickman	
NE#: 31-10917		Collection Date: 6-24-26 to 6-26-26	
Completed By: Wade Luther			Date: 7-16-2026

	Lead Result	Address (Kitchen or Bathroom)	Tier	Copper Result	Address	Tier
20						
19						
18						
17						
16						
15						
14						
13						
12						
11						
10	7.09	422 Village View		270	422 Village View	
9	2.33	335 Locust St		170	630 Maple St	
8	1.22	108 Brentwood		154	113 Wagon Train Ave	
7	1.08	762 E 2nd		147	335 Locust St	
6	.853	113 Wagon Train Ave.		116	104 Concord Ave	
5	.853	334 Locust St.		103	762 E 2nd	
4	.676	630 Maple St.		83.5	334 Locust St.	
3	.660	104 Concord Ave		71.3	108 Brentwood	
2	<RL	118 Concord Ave		69.6	118 Concord Ave	
1	<RL	220 Chestnut St		54.0	220 Chestnut St	

START WITH THE LOWEST LEAD AND COPPER RESULT IN ROW 1!

90 th Percentiles	
Lead:	2.33
Copper:	170

Please complete the *Lead and Copper Results Report* ("Form 5") form and email this form to:
DWEE.ECMupload@nebraska.gov